SIEMENS

WIRE CONNECTOR 4 CABLES 3 PCS. ACCESSORY FOR: 3VA15/25 1000

Model	
product brand name	SENTRON
product designation	accessories
Product version	'wire connector
Accessories	Wire connector
General technical data	
designation / of the terminal	TA4.3
Voltage	
Current	
Mechanical Design	
Connections according IEC	
connectable conductor cross-section	
● for copper cable / stranded / minimum	120 mm²
● for copper cable / stranded / maximum	240 mm²
● for aluminum cable / stranded / minimum	120 mm²
● for aluminum cable / stranded / maximum	240 mm²
stripped length	23.1 44.5
Connetctions according UL	
permissible temperature / of connectable conductor / according to UL 486A-486B	90 °C
connectable conductor cross-section	
● for copper cable / stranded / minimum	4/0
● for copper cable / stranded / maximum	500
● for copper cable / finely stranded / minimum	4/0
● for copper cable / finely stranded / maximum	500
● for aluminum cable / stranded / minimum	4/0
● for aluminum cable / stranded / maximum	500
tightening torque / when using copper cables	
● stranded	4/0 - 500 kcmil: 325 lb-in
● finely stranded	4/0 - 500 kcmil: 325 lb-in
Certificates	

General Product Approval	EMC	Declaration of Conformity
[Miscellaneous](#)		

Declaration of Conformity					Shipping Approval
CE EG-Konf.	CE EG-Konf.	CE EG-Konf.	CE EG-Konf.	CE EG-Konf.	Lloyd's Register LRS

other

Manufacturer Declaration   Miscellaneous

Further information

Information- and Downloadcenter (Catalogs, Brochures,…)
http://www.siemens.com/lowvoltage/catalogs

Industry Mall (Online ordering system)
https://mall.industry.siemens.com/mall/en/en/Catalog/product?mlfb=3VA9603-0JJ43

Service&Support (Manuals, Certificates, Characteristics, FAQs,...)
https://support.industry.siemens.com/cs/ww/en/ps/3VA9603-0JJ43

Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, ...)
http://www.automation.siemens.com/bilddb/cax_en.aspx?mlfb=3VA9603-0JJ43

Tender specifications
http://www.siemens.com/specifications

12.21.2020

last modified: 12/20/2020

12.21.2020